

Attestation

On 27 January 2012, Eurofins Product Testing A/S received a sample of a levelling compound named

Sikafloor-Level 30 Sika Österreich GmbH

The emission of organic compounds from the sample was measured in accordance with the test method as defined by GEV in its version by 09.11.2010. (See report No. G14429C)

Evaluation of the test result according to EC 1 PLUS:

- Carcinogenic substances were not detectable after 3 and after 10 days.
 - The sum of VOC ("TVOC") after 3 days was below the limit of 750 µg/m³.
 - The sum of VOC ("TVOC") after 10 days was below the limit of 60 µg/m³.
 - The sum of SVOC after 10 day was below the limit of 40 µg/m³.
 - After 10 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was below the limit of 1.
 - The sum of VOC without LCI-value after 10 days was below the limit of 40 µg/m³.
 - The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.
-

This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label a license has to be applied for at the GEV, Düsseldorf, Germany.

A license can only be granted for ready-to use products, if some additional requirements on contents of certain chemicals (e.g. solvent-free) are fulfilled.

10 April 2012



Thomas Neuhaus
Head of product emission test centre



Dr. Arja Valtanen
Analytical Service Manager

Eurofins Product Testing A/S
Smødeskovvej 38
DK-8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75